

Tarmac Cement National Laboratory

Yelsway Lane Waterhouses Staffordshire ST10 3AZ

05/09/2024

#### **Composition of Ground Granulated Blastfurnace Slag**

#### Dunkirk EN 15167-1 GGBS (0099/CPR/B34/0001)

Based on the June 2024 monthly composite sample: 2265

| Property                             |                                |       | Value | BS EN 15167-1 Limit |
|--------------------------------------|--------------------------------|-------|-------|---------------------|
| Magnesia                             | MgO                            | %     | 7.41  | ≤ 18.0%             |
| Sulfate                              | SO₃                            | %     | 0.20  | ≤ 2.5%              |
| Sulfide                              | S2-                            | %     | 0.87  | ≤ 2.0%              |
| Chloride                             | Cl-                            | %     | 0.01  | ≤ 0.1%              |
| Alkalis                              | Na₂Oeq                         | %     | 0.47  | -                   |
| Alumina                              | Al <sub>2</sub> O <sub>3</sub> | %     | 13.40 | ≤ 14%*              |
| Fineness                             | SSA                            | m²/kg | 478   | ≥ 275 m²/kg         |
| 7 Day Activity Index – May Sample    |                                | %     | 55    | >40%                |
| 28 Day Activity Index – May Sample   | e                              | %     | 81    | >65%                |
| Declared Mean Alkali Content         | Na <sub>2</sub> Oeq            | %     | 0.70  | -                   |
| Declared Maximum Chloride<br>Content | Cl-                            | %     | 0.05  | -                   |

<sup>\*</sup>Upper limit in BS 8500 for use in '+SR' combinations

For and on behalf of Tarmac Cement:

S. Chudley

**Simon Chudley** 

National Commercial Technical Manager Tarmac Cement

#### **TARMAC.COM**



#### Conformity of Ground Granulated Blast Furnace Slag to BS 8500-2: Annex B Dunkirk EN 15167-1 GGBS (1164-CPR-LGM002)

Based on the composite samples for the Month of: June 2024

| Constituent     | Source   |
|-----------------|----------|
| EN 15167-1 GGBS | Dunkirk  |
| EN 197-1 CEM I  | Aberthaw |

The results of compressive strength testing (in accordance with BS EN 196-1) on a 50:50 blend of CEM I with GGBS were:

| 7 Day Strength (MPa)  | 26.3 |
|-----------------------|------|
| 28 Day Strength (MPa) | 49.5 |

Based on equivalent results obtained for the last **4** Months, the permitted proportions of combinations conforming to the requirements of Annex B of BS 8500-2 are:

| Strength Class of Combination | GGBS Content (%) |     |
|-------------------------------|------------------|-----|
|                               | Min              | Max |
| 32,5L                         | 43               | 75  |
| 42,5L                         | 6                | 56  |
| 52,5L                         | 6                | 21  |

| BS 8500-2 Combination | GGBS Content (%) |     |
|-----------------------|------------------|-----|
| Designation           | Min              | Max |
| CIIS                  | 6                | 35  |
| CIIIA                 | 36               | 65  |
| CIIIB                 | 66               | 80  |

For and on behalf of Tarmac Cement: **Simon Chudley** 

National Commercial Technical Manager Tarmac Cement TARMAC.COM



# Conformity of Ground Granulated Blast Furnace Slag to BS 8500-2: Annex B Dunkirk EN 15167-1 GGBS (1164-CPR-LGM002)

Based on the composite samples for the Month of: June 2024

| Constituent          | Source   |
|----------------------|----------|
| EN 15167-1 GGBS      | Dunkirk  |
| EN 197-1 CEM II/A-LL | Aberthaw |

The results of compressive strength testing (in accordance with BS EN 196-1) on a 50:50 blend of CEM II/A-LL with GGBS were:

| 7 Day Strength (MPa)  | 30.2 |
|-----------------------|------|
| 28 Day Strength (MPa) | 49.6 |

Based on equivalent results obtained for the last **4** Months, the permitted proportions of combinations conforming to the requirements of Annex B of BS 8500-2 are:

| Strength Class of Combination | GGBS Content (%) |     |
|-------------------------------|------------------|-----|
|                               | Min              | Max |
| 32,5L                         | 42               | 73  |
| 42,5L                         | 6                | 55  |
| 52,5L                         |                  |     |

| BS 8500-2 Combination | GGBS Content (%) |     |
|-----------------------|------------------|-----|
| Designation           | Min              | Max |
| CIIS                  | 6                | 35  |
| CIIIA                 | 36               | 65  |
| CIIIB                 | 66               | 80  |

For and on behalf of Tarmac Cement: **Simon Chudley** 

National Commercial Technical Manager Tarmac Cement TARMAC.COM



#### Conformity of Ground Granulated Blast Furnace Slag to BS 8500-2: Annex B Dunkirk EN 15167-1 GGBS (1164-CPR-LGM002)

Based on the composite samples for the Month of: June 2024

| Constituent     | Source  |
|-----------------|---------|
| EN 15167-1 GGBS | Dunkirk |
| EN 197-1 CEM I  | Cauldon |

The results of compressive strength testing (in accordance with BS EN 196-1) on a 50:50 blend of CEM I with GGBS were:

| 7 Day Strength (MPa)  | 28.5 |
|-----------------------|------|
| 28 Day Strength (MPa) | 51.4 |

Based on equivalent results obtained for the last **3** Months, the permitted proportions of combinations conforming to the requirements of Annex B of BS 8500-2 are:

| Strength Class of Combination | GGBS Content (%) |     |
|-------------------------------|------------------|-----|
|                               | Min              | Max |
| 32,5L                         | 45               | 76  |
| 42,5L                         | 6                | 58  |
| 52,5L                         | 6                | 35  |

| BS 8500-2 Combination | GGBS Content (%) |     |
|-----------------------|------------------|-----|
| Designation           | Min              | Max |
| CIIS                  | 6                | 35  |
| CIIIA                 | 36               | 65  |
| CIIIB                 | 66               | 80  |

For and on behalf of Tarmac Cement: **Simon Chudley** 

National Commercial Technical Manager Tarmac Cement TARMAC.COM



# Conformity of Ground Granulated Blast Furnace Slag to BS 8500-2: Annex B Dunkirk EN 15167-1 GGBS (1164-CPR-LGM002)

Based on the composite samples for the Month of: June 2024

| Constituent     | Source  |
|-----------------|---------|
| EN 15167-1 GGBS | Dunkirk |
| EN 197-1 CEM I  | Hope    |

The results of compressive strength testing (in accordance with BS EN 196-1) on a 50:50 blend of CEM I with GGBS were:

| 7 Day Strength (MPa)  | 29.1 |
|-----------------------|------|
| 28 Day Strength (MPa) | 53.9 |

Based on equivalent results obtained for the last **4** Months, the permitted proportions of combinations conforming to the requirements of Annex B of BS 8500-2 are:

| Strength Class of Combination | GGBS Content (%) |     |
|-------------------------------|------------------|-----|
|                               | Min              | Max |
| 32,5L                         | 51               | 77  |
| 42,5L                         | 11               | 62  |
| 52,5L                         | 6                | 36  |

| BS 8500-2 Combination | GGBS Content (%) |     |
|-----------------------|------------------|-----|
| Designation           | Min              | Max |
| CIIS                  | 6                | 35  |
| CIIIA                 | 36               | 65  |
| CIIIB                 | 66               | 80  |

For and on behalf of Tarmac Cement: **Simon Chudley** 

National Commercial Technical Manager Tarmac Cement TARMAC.COM



# Conformity of Ground Granulated Blast Furnace Slag to BS 8500-2: Annex B Dunkirk EN 15167-1 GGBS (1164-CPR-LGM002)

Based on the composite samples for the Month of: June 2024

| Constituent     | Source  |
|-----------------|---------|
| EN 15167-1 GGBS | Dunkirk |
| EN 197-1 CEM I  | Lemona  |

The results of compressive strength testing (in accordance with BS EN 196-1) on a 50:50 blend of CEM I with GGBS were:

| 7 Day Strength (MPa)  | 27.8 |
|-----------------------|------|
| 28 Day Strength (MPa) | 52.9 |

Based on equivalent results obtained for the last **5** Months, the permitted proportions of combinations conforming to the requirements of Annex B of BS 8500-2 are:

| Strength Class of Combination | GGBS Content (%) |     |
|-------------------------------|------------------|-----|
|                               | Min              | Max |
| 32,5L                         | 49               | 80  |
| 42,5L                         | 27               | 64  |
| 52,5L                         | 6                | 40  |

| BS 8500-2 Combination | GGBS Content (%) |     |
|-----------------------|------------------|-----|
| Designation           | Min              | Max |
| CIIS                  | 6                | 35  |
| CIIIA                 | 36               | 65  |
| CIIIB                 | 66               | 80  |

For and on behalf of Tarmac Cement: **Simon Chudley** 

National Commercial Technical Manager Tarmac Cement TARMAC.COM



#### Conformity of Ground Granulated Blast Furnace Slag to BS 8500-2: Annex B Dunkirk EN 15167-1 GGBS (1164-CPR-LGM002)

Based on the composite samples for the Month of: June 2024

| Constituent     | Source   |
|-----------------|----------|
| EN 15167-1 GGBS | Dunkirk  |
| EN 197-1 CEM I  | Limerick |

The results of compressive strength testing (in accordance with BS EN 196-1) on a 50:50 blend of CEM I with GGBS were:

| 7 Day Strength (MPa)  | 27.3 |
|-----------------------|------|
| 28 Day Strength (MPa) | 50.2 |

Based on equivalent results obtained for the last **5** Months, the permitted proportions of combinations conforming to the requirements of Annex B of BS 8500-2 are:

| Strength Class of Combination | GGBS Content (%) |     |
|-------------------------------|------------------|-----|
|                               | Min              | Max |
| 32,5L                         | 48               | 75  |
| 42,5L                         | 6                | 59  |
| 52,5L                         | 6                | 34  |

| BS 8500-2 Combination | GGBS Content (%) |     |
|-----------------------|------------------|-----|
| Designation           | Min              | Max |
| CIIS                  | 6                | 35  |
| CIIIA                 | 36               | 65  |
| CIIIB                 | 66               | 80  |

For and on behalf of Tarmac Cement: **Simon Chudley** 

National Commercial Technical Manager Tarmac Cement TARMAC.COM



#### Conformity of Ground Granulated Blast Furnace Slag to BS 8500-2: Annex B Dunkirk EN 15167-1 GGBS (1164-CPR-LGM002)

Based on the composite samples for the Month of: June 2024

| Constituent     | Source  |
|-----------------|---------|
| EN 15167-1 GGBS | Dunkirk |
| EN 197-1 CEM I  | Platin  |

The results of compressive strength testing (in accordance with BS EN 196-1) on a 50:50 blend of CEM I with GGBS were:

| 7 Day Strength (MPa)  | 28.6 |
|-----------------------|------|
| 28 Day Strength (MPa) | 53.5 |

Based on equivalent results obtained for the last **5** Months, the permitted proportions of combinations conforming to the requirements of Annex B of BS 8500-2 are:

| Strength Class of Combination | GGBS Content (%) |     |
|-------------------------------|------------------|-----|
|                               | Min              | Max |
| 32,5L                         | 49               | 77  |
| 42,5L                         | 6                | 62  |
| 52,5L                         | 6                | 35  |

| BS 8500-2 Combination | nation GGBS Conte |     |
|-----------------------|-------------------|-----|
| Designation           | Min               | Max |
| CIIS                  | 6                 | 35  |
| CIIIA                 | 36                | 65  |
| CIIIB                 | 66                | 80  |

For and on behalf of Tarmac Cement: **Simon Chudley** 

National Commercial Technical Manager Tarmac Cement TARMAC.COM



# Conformity of Ground Granulated Blast Furnace Slag to BS 8500-2: Annex B Dunkirk EN 15167-1 GGBS (1164-CPR-LGM002)

Based on the composite samples for the Month of: June 2024

| Constituent     | Source   |
|-----------------|----------|
| EN 15167-1 GGBS | Dunkirk  |
| EN 197-1 CEM I  | Tunstead |

The results of compressive strength testing (in accordance with BS EN 196-1) on a 50:50 blend of CEM I with GGBS were:

| 7 Day Strength (MPa)  | 25.6 |
|-----------------------|------|
| 28 Day Strength (MPa) | 54.2 |

Based on equivalent results obtained for the last **5** Months, the permitted proportions of combinations conforming to the requirements of Annex B of BS 8500-2 are:

| Strength Class of Combination | GGBS Content (%) |     |
|-------------------------------|------------------|-----|
|                               | Min              | Max |
| 32,5L                         | 52               | 77  |
| 42,5L                         | 23               | 58  |
| 52,5L                         | 6                | 41  |

| BS 8500-2 Combination | GGBS Content (%) |     |
|-----------------------|------------------|-----|
| Designation           | Min              | Max |
| CIIS                  | 6                | 35  |
| CIIIA                 | 36               | 65  |
| CIIIB                 | 66               | 80  |

For and on behalf of Tarmac Cement: **Simon Chudley** 

National Commercial Technical Manager Tarmac Cement TARMAC.COM